

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-0559:114

Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Silent Knight, 7550 Meridian Circle, Maple Grove MN 55369-4927
Contact: Brian Foltz *(763) 493-6400

DESIGN: Model 5104. Provides automatic, manual and waterflow service when used as a central station protective premise unit. Intended to monitor various initiating devices and transmit to a central station receiving unit various preprogrammed alarm and trouble signals. Refer to listee's data sheet for detailed product description, electrical rating and operational considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 16, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager